



CLARK COUNTY DEPARTMENT OF BUILDING

Field Inspection Guideline



SUBJECT: Listing Labeling			FIG-E-001
Effective Date: January 29, 2000	Revised: May 29, 2014	Approved By: BAT	
Code Chapter: 2011 NEC Sect 110.3 (A) and (B) Annex A			Page 1 of 1

Interpretation:

Section 110.3 (B) does not, in itself, require listing or labeling. It does, however, require considerable evaluation of equipment. Section 110.2 requires that equipment be acceptable only if approved. The term approved is defined in Article 100 as “acceptable to the authority having jurisdiction.” Before issuing approval, the authority having jurisdiction may require evidence of compliance with Section 110.3(A)(1). The most common form of this evidence that is considered acceptable by authorities having jurisdiction is a listing or labeling by a third party.

Field Application:

Installations of display cases, display shelving, or modular office furniture containing electrical wiring shall comply with either of the following:

1. Be listed by an approved third party
2. Field installed wiring
 - a. The electrical work must be done under a valid electrical permit.
 - b. Wiring may be field installed with any wiring method permitted by the current electrical code, and must be inspected by the field inspector to verify compliance with those requirements.

Revision History:

Reference #	Title	Effective Date	Revised	Reviewed
FIG-E-001	Listing Issues	January 29, 2000	May 30, 2013	
FIG-E-001	Listing Labeling		May 29, 2014	